

## MUAYENE - DENEY SONUÇLARI TEST RESULTS

### DESCRIPTION OF THE SAMPLE

Projector with LED, brand UNIVERSAL, MINI ROBUST model that belongs to UNIVERSAL ELEKTRONİK TEKNOLOJİ LTD.ŞTİ.

### TESTS AND EXPERIMENTS

1) DEGREES OF PROTECTION PROVIDED BY ENCLOSURES FOR ELECTRICAL EQUIPMENT AGAINST EXTERNAL MECHANICAL IMPACTS (TS EN 62262:November 2002)

The sample is subjected, as specified in clause 7 in TS EN 60068-2-75 standard, according to the free fall test method with a IK10 impact hammer sequentially 3 times with 20J energy mechanical shock. After the test no cracking, fracture or opening is seen which may disturb the safe operation of the sample, as mentioned in in the Clause 6.5. Mechanical protection is enough for the required qualification.

### PHOTOGRAPHS OF SAMPLE

